



La Cumbre Mutual Water Company

695 Via Tranquila Santa Barbara 967-2376

2022 CONSUMER CONFIDENCE REPORT DATA

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Please see last page for key to abbreviations.

Parameter	Units	State MCL	PHG (MCLG)	Range Average	SOURCE		Major Sources in Drinking Water
					GROUND WATER	SURFACE WATER	

PRIMARY STANDARDS--Mandatory Health-Related Standards

CLARITY (a)

Combined Filter Effluent Turbidity	NTU	TT=1 NTU	Highest Single Measurement	NA	0.05	Soil runoff
				NA	100% Samples <= 0.3 NTU	

MICROBIOLOGICAL (b)

Total Coliform Bacteria (Distribution System)	Samples	5% of monthly samples (b)	(0)	Reporting		Naturally present in the environment	
				Value	0 Positives		1 Positives
Fecal Coliform and E. coli (Distribution System)	Samples	(b)	(0)	Range	0 Positives	Human and animal fecal waste	
				Average	0 Positives		0 Positives
				Highest	0 Positives		0 Positives

Disinfectant Byproducts - Disinfectant Residuals - Disinfection Byproduct Precursors

Total Trihalomethanes (Distribution System) (c)	ppb	80	NA	Range	15.9 - 34.9	0.4 - 59	By-product of drinking water disinfection
				Average	25.7	49	
Haloacetic Acids (c) (Distribution System)	ppb	60	NA	Range	5.8 - 10.6	ND - 21	By-product of drinking water disinfection
				Average	7.85	22	
Disinfectant - Free Chlorine Residual	ppm	MRDL as Cl2 4.0	MRDLG as Cl2 4.0	Range	0.2 - 3.4 (d)	ND - 2.2	Measurement of the disinfectant used in the production of drinking water
				Average	0.9 (d)	0.73	
Control of DBP precursors - TOC	ppm	TT	NA	Range	0.36 - 0.96 (d)	2.1 - 3.8	TOC has no health effects. However, it provides a medium for the formation of disinfection by-products. Various natural and manmade sources
				Average	0.63 (d)	2.7	

INORGANIC CHEMICALS

Aluminum	ppb	1000	600	Range	ND - 120	ND - 180	Residue from water treatment process; Erosion of natural deposits
				Average	24	56	
Arsenic	ppb	10	0.004	Range	ND	ND	Erosion of natural deposits
				Average	NA	NA	
Barium	ppm	1	2	Range	ND	ND	Erosion of natural deposits
				Average	NA	NA	
Fluoride	ppm	2	1	Range	0.38 - 0.63	0.39 - 0.51	Erosion of natural deposits; water additive for tooth health
				Average	0.47	0.46	
Nitrate (as NO3)	ppm	45	45	Range	ND - 7.3	0.44 - 10.5	Runoff & leaching from fertilizer use; sewage; natural erosion
				Average	1.78	3.80	
Hexavalent chromium, Cr VI	ppb	10	0.02	Range	ND	ND	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits
				Average	NA	NA	

LEAD & COPPER RULES - Monitored at the customers tap. Number of sites exceeded Action Level = 0

Copper	ppm	1.3	0.3	Value	0.80	NA	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
				90th %			
Lead	ppb	15	0.2	Value	ND	NA	Internal corrosion of household plumbing systems; discharges from industrial manufactures; erosion of natural deposits.
				90th %			

RADIOCHEMISTRY - Radioactive Contaminants

Gross Alpha	pCi/L	15	MCLG, 0	Range	ND - 5.1	ND	Erosion of natural deposits
				Average	3.0	NA	
Radium 228	pCi/L	N/A	N/A	Range	0 - 0.283	ND	Erosion of natural deposits
				Average	0.0566	NA	

SECONDARY STANDARDS--Aesthetic Standards

Chloride	ppm	500	NA	Range	26 - 130	30 - 36	Runoff/leaching from natural deposits; seawater influence
				Average	78.4	33	
Color (ACU)	Units	15	NA	Range	3 - 5	ND	Naturally occurring organic materials
				Average	4	NA	
Copper	ppb	1000	NA	Range	ND	ND	Corrosion of plumbing systems; erosion of natural deposits; leaching from wood preservatives
				Average	NA	NA	
Iron	ppb	300	NA	Range	ND - 26	ND	Leaching from natural deposits; industrial wastes
				Average	1	NA	
Manganese	ppb	50	NA	Range	ND - 200	ND	Leaching from natural deposits
				Average	105.4	NA	
Odor Threshold	Units	3	NA	Range	1 - 4	1 - 4	Naturally occurring organic materials
				Average	2.75	3	
Specific Conductance	µmho/cm	1600	NA	Range	990 - 1700	883 - 1016	Substances that form ions when in water; seawater influence.
				Average	1338	952	
Sulfate	ppm	500	NA	Range	260 - 460	240 - 310	Runoff/leaching from natural deposits; industrial wastes
				Average	320	280	
Total Dissolved Solids	ppm	1000	NA	Range	700 - 1200	542 - 736	Runoff/leaching from natural deposits; seawater influence
				Average	910	640	
Turbidity (Monthly)	NTU	5	NA	Range	0.05 - 1.70	0.10 - 0.25	Soil runoff
				Average	1.0	0.16	
Zinc	ppm	5.0	NA	Range	ND - 0.081	ND	Naturally occurring in trace amounts, but can be detected in soft, acidic water systems
				Average	0.032	NA	

Additional Parameters (Unregulated):

Alkalinity (Total) as CaCO3 equivalents	ppm	NA	NA	Range	220 - 360	170 - 209	Runoff/leaching from natural deposits; seawater influence
				Average	296	185	
Calcium as Ca	ppm	NA	NA	Range	93 - 190	77 - 96	Runoff/leaching from natural deposits; seawater influence
				Average	140.6	87	
Hardness (Total) as CaCO3	ppm	NA	NA	Range	350 - 690	340 - 428	Leaching from natural deposits
				Average	508	386	
Magnesium	ppm	NA	NA	Range	30 - 54	37 - 50	Runoff/leaching from natural deposits; seawater influence
				Average	38.8	45	
pH	Units	NA	NA	Range	7.6 - 7.8	7.53 - 7.84	Runoff/leaching from natural deposits; seawater influence
				Average	7.68	7.70	
Potassium	ppm	NA	NA	Range	1.9 - 3.8	3.8 - 5.0	Runoff/leaching from natural deposits; seawater influence
				Average	2.56	4.5	
Sodium	ppm	NA	NA	Range	73 - 140	54 - 65	Runoff/leaching from natural deposits; seawater influence
				Average	103.8	60	

Constituents of Concern:

Boron	ppb	1000 (AL)	NA	Range	130 - 350	370 - 390	Runoff/leaching from rocks and soil, wastewater, and fertilizers/pesticides.
				Average	232	380	

Water System Name: La Cumbre Mutual Water Company

Report Date: June 2023

In 2022, 54% of our water was from our wells, the remaining 46% was State Project Water after flowing into Lake Cachuma and being treated by the Santa Barbara City Cater Surface Water Treatment Plant. Therefore, the surface water quality portion of this report comes from the city of Santa Barbara. Sections of our service area along State Street and Modoc Road receive water that was treated entirely by the city of Santa Barbara.

Time and place of regularly scheduled board meetings for public participation: Once a month at 695 Via Tranquila, please call for exact date and times 805 967-2376.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the State Water Resources Control Board (SWRCB) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. SWRCB regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

This report lists all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The SWRCB requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

Additional General Information On Drinking Water:

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791 or www.epa.gov/safewater/.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791 or www.epa.gov/safewater/.

ABBREVIATIONS AND NOTES

Type of water sources in use: Five ground water wells and State Project surface water from Lake Cachuma through Santa Barbara City Cater Treatment Plant.

Name of Sources: Well #16, Well #17, Well #18, Well #19 & Well #21 and seven metered connections to Santa Barbara City Water. **Note:** Depending on where you live, our water is a mixture of groundwater and surface water.

Water Quality Report: Listed are substances detected in the drinking water. Not listed are more than 135 regulated and unregulated substances that were below the laboratory detection level.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. La Cumbre Water Co. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Definitions:

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the Environmental Protection Agency.

Maximum Contaminate Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency

Maximum Contaminate Level (MCLs): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant (chlorine) added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U. S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant (chlorine) added for water treatment that may not be exceeded at the consumer's tap.

DBP: Disinfection Byproducts

Regulatory Action Level (AL): The concentration of a contaminant which if exceeded, triggers a treatment or other requirement which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCL's for contaminants that effect taste, odor or appearance of drinking water. Contaminants with SDWS do not affect the health at MCL levels.

Unregulated Contaminant Monitoring Regulations (UCMR): Data generated by the new UCMR will be used to evaluate and prioritize contaminants on the Drinking Water Contaminant Candidate List, a list of contaminants EPA is considering for possible new drinking water standards. Also known as "State Regulated Contaminants with No MCLs".

NA: Not Applicable

ND: Not Detected

Footnotes:

- Turbidity (NTU) is a measure of the cloudiness of the water and it is a good indicator of the effectiveness of our filtration system. Monthly turbidity values for ground water are listed in the Secondary Standards section.
- Total coliform MCLs: The State MCL for coliforms is no more than 1 per month for water systems which collect less than 40 samples per month (La Cumbre Water). Systems which collect over 40 routine samples may not have more than 5% positive per month.
- Compliance based on the quarterly annual average distribution system samples.
- Although reported under ground water these readings were taken from the distribution system and are a combination of ground and surface water.

Abbreviations

"<" = Less Than
AL = Regulatory Action Level
ACU = Apparent Color Units
MCL = Maximum Contaminant Level
MCLG = Maximum Contaminant Level Goal
MRDL = Maximum Residual Disinfectant Level
MRDLG = Maximum Residual Disinfectant Goal
NA = not applicable
NC = Not Collected
ND = None Detected
NTU = Nephelometric Turbidity Units
pCi/L = PicoCuries per liter
PHG = Public Health Goal
ppb = parts per billion, or micrograms per liter (µg/L)
ppm = parts per million, or milligrams per liter (mg/L)
TOC = Total Organic Carbon
TT = Treatment Technique
µmho/cm = micromhos per centimeter
(unit of specific conductance of water)

The Source Water Assessment and Protection Program information and Vulnerability Assessment are available at our office 695 Via Tranquila, Santa Barbara CA 93110. For more information contact Mike Alvarado, General Manager 805 967-2376 x115.